

# Declaration of Performance

## DoP / DoP010 de



1. Unique identification code of the product type:

**Product type: Powered Smoke and Heat Exhaust Ventilator**  
**Product ID: 150695**  
**Product name: DHN 280 D2 F4 30**

2. Type, batch or serial number or another indicator for the identification of the building product according to Article 11, Paragraph 4:

**see nameplate**

3. By the manufacturer intended use or intended uses according to the applicable harmonized technical specification:

**Should be installed as a part of a mechanical smoke and heat extraction system in a building**

4. Name, registered commercial name or registered trademark and contact address of the manufacturer according to Article 11, Paragraph 5:

**ruck Ventilatoren GmbH**  
**Max-Planck-Str. 5**  
**DE 97944 Boxberg**

5. Name and contact address of authorised representative:

-

6. System or systems for the evaluation and verification of the performance constancy of the building product according to Annex V of the Building Product Regulation:

**System 1**

7. In case of a Declaration of Performance concerning a building product, which falls under a harmonized norm:

The notified Product Certification Body ZAG Slovenian National Building and Civil Engineering Institute, No. 1404 has carried out the initial testing of the relevant properties of the product.

The notified Product Certification Body ZAG Slovenian National Building and Civil Engineering Institute, No. 1404 has carried out the initial testing of the plant and factory production monitoring and carries out the continuous monitoring, assessment and approval of factory production monitoring.

**104-CPR-3171**

8. Declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

-

## 9. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
<b>Response delay:</b> Open under wind load within a given period of time. Open under snow load within a given period of time.	0 s SL 0	<b>EN 12101-3: 2015</b>
<b>Operation reliability:</b> Application categories Motor power	with double function F, 80K	
<b>Efficiency in discharge of smoke/hot gas:</b> Maintaining of gas and smoke volume flow rate and pressure during the control of the discharging of smoke and hot gas.	$\pm 10 \%$	
Fire resistance	F 400 (120)	
<b>Ability to be opened under ambient conditions:</b> Open under wind load within a given period of time. Open under snow load within a given period of time.	0 s SL 0	
Consistency of the operation reliability	F, 80K	

## 9.b

Supplementary information on installation and applications according to table F.8 EN 12101-3: 2015	
<b>Fire resistance</b>	
Free classification for informative purposes	<b>F 200</b> <b>F 300</b> <b>F 400 (120)</b> <b>F 400 (90)</b>
<b>Location of extraction device and thermal insulation, if available</b>	
outside the building without thermal insulation	<b>X</b>
outside the building with thermal insulation	
inside the building, outside the fire area, without insulation	
inside the building, outside the fire area, with insulation	
inside the fire area without thermal insulation	
inside the fire area with thermal insulation	

<b>Installation</b>	
horizontal axis, floor installation	
horizontal axis, wall suspension	
horizontal axis, ceiling suspension	
vertical axis, $\Delta p$ upwards	<b>X</b>
vertical axis, $\Delta p$ downwards	
vertical axis, wall suspension	
vertical axis, ceiling suspension	
<b>Flexible connectors, tested on the extraction device</b>	
flexible connection on the suction side	<b>X</b>
flexible connection on the outlet side	
<b>Cooling air</b>	
At outdoor installation no external air supply cooling required	
<b>Application</b>	
It is a dual function device	<b>X</b>
Only as an emergency operation device	
Thermally insulated	
Not thermally insulated	<b>X</b>

- 10.** The performance of the product according to Numbers 1 and 2 corresponds to the declared performance under Number 9:

Sole responsibility for creating this Declaration of performance pertains to the manufacturer under Number 4.



Boxberg, 23.04.2020  
Place and date of issue

Fabian Schmelz (Technical Director)  
Name and signature of authorized person

Page 3 / 3  
150695\_plf4\_k10001\_en\_20200423